CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250161

Address: 2623 SW TRACKER LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Drew Fischer Failed Thursday, August 28,

Residential 2025

Corrective Action Required:

1 Misc 2623 SW Tracker

- house numbers missing

- Romex coming out of stone on front of house must be properly landed in a

box

- Sump outlet must be marked as non gfci

- Lockout needed for water heater in main panel

Laundry room outlet must be gfciSeal all penetrations in exterior

- Outlet needed within 25' of AC unit on exterior of home

- Install splash blocks and sump discharge pipe

Comments: