

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250160
Address: 2623 SW FIREFLY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Wes Bears	Failed	Friday, August 29, 2025

Corrective Action Required:

1	Miscellaneous Correction	2623 -code R319 in the 2018 IRC is the address code that's to be followed -spark ring needed in master bedroom -outlet in master bathroom at toilet not working
---	-----------------------------	--

Comments: