

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251162

Address: 638 SE BRADFREE ST, LEES SUMMIT, MO 64063640 SE BRADFREE ST, LEES SUMMIT, MO 64063642
SE BRADFREE ST, LEES SUMMIT, MO 64063636 SE BRADFREE ST, LEES SUMMIT, MO
64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mitchell Schwarz	Failed	Friday, August 29, 2025

Corrective Action Required:

1	Misc	Exterior sheathing inspection only. No plans on site to confirm portal framing locations or sheathing nail pattern requirements Nail all truss ends to sheathing where missing
---	------	--

Comments: