



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION

220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20120429
Address: 1198 NE DOUGLAS ST, LEES SUMMIT, MO 64086
Inspected On: Thursday, March 22, 2012
Inspected By: John Borns
Expiration Date: 12/31/1899 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Thursday, March 22, 2012

Corrective Action Required:

1	MISC	INSTALLATION OF LIGHTED SIGN SUBJECT TO APPROVAL WHEN INSTALLED. PER NEC 600-3: IF INTERNALLY LIGHTED MUST BE UL SHOP-LABELED PER 600.3. INSTALL NO NON-LISTED SIGN.
---	------	--

Corrective Action Required:

4	MISC	IFGC 404.8: EXPOSED METALLIC GAS PIPING MUST BE PERMANENTLY PROTECTED WITH PAINT OR BY OTHER APPROVED MEANS.
---	------	--

Corrective Action Required:

5	MISC	ADDRESS LABELING OF GAS SERVICE ENTRY PIPE: AFFIX PERMANENT TAG/LABEL TO ENTRY PIPE. FELT TIP MARKER NOT APPROVABLE.
---	------	--

Comments: CALL TO REQUEST RE-INSPECTION WHEN ABOVE ISSUES ARE

RESOLVED / COMPLETED.