



Microbac Laboratories, Inc., Lenexa

CERTIFICATE OF ANALYSIS

3IH0148

City of Lee's Summit - Public Works Dept.

Project Name: Douglas Station

Accts Payable
220 SE Green Str
Lees Summit, MO 64063

Project / PO Number: N/A
Received: 08/27/2025
Reported: 08/28/2025

Analytical Testing Parameters

Client Sample ID:	#2 Douglas Station	Collected By:	Allen, Joshua
Sample Matrix:	Drinking Water	Collection Date:	08/27/2025 9:30
Lab Sample ID:	3IH0148-01		

Determination of Microbiological Parameters	Result	RL	Units	Note	Prepared	Analyzed	Analyst
9223B-QT							
Total Coliforms	<1.0	1.0	MPN/100ml		08/27/25 1450	08/27/25 1518	JAD
E. Coli	<1.0	1.0	MPN/100ml		08/27/25 1450	08/27/25 1518	JAD

Definitions

RL: Reporting Limit

Report Comments

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:

Sue Thompson
Client Services Manager
08/28/25 17:13