

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20251357  
Address: 2132 SW WHEATFIELD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Tyler Schreck	Partial	Wednesday, September 03, 2025

Corrective Action Required:

1	DCM3 ESC REQUIRED 2 DAY	8/21/25 Tyler S. Silt fence is down in multiple areas and gravel and debris needs swept off of the road and curb line. The porta-potty need to be moved and cannot be on public roadways. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. Corrections need to be done by the 27th or a stop work order will be issued.
---	----------------------------	---

**Comments:**