

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250160
Address: 2623 SW FIREFLY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|----------------------------------|
| Occupancy Inspection - Codes Residential | Khanh Nguyen | Failed | Wednesday, September 03, 2025 |

Corrective Action Required:

| | | |
|---|-----------------------------|--|
| 1 | Miscellaneous Correction | -spark ring needed in master bedroom receptacle boxes recessed behind combustible wall finish |
|---|-----------------------------|--|

**Footing inspection report has not been submitted to city; driveway not
approved

Comments: