



**LEE'S SUMMIT**  
MISSOURI



---

**FIRE DEPARTMENT**

**Prevention Division**  
**(816)969-1300**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20253506	Date:	September 04, 2025
Project Title:	SONNYS	Applicant:	
Location:			
2201 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064	FIRE ALARM SOLUTIONS		
	3150 MERCIER STREET STE 520		
	KANSAS CITY, MO 64111		
Type of Work:			
Occupancy Group:	S-1		
Description:	SONNYS - NEW TENANT FINISH	Primary:	(816) 753-4660
FOR OFFICE AND WAREHOUSE DISTRIBUTION FOR			
CARWASH SOAP			
Construction Type:	Type VB (Unprotected)		
Map Page:			

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Alarm Plan Review**

**Reviewed By: Craig Hill**

**Released for Construction**

1. 2018 IFC 904.4.2- Alarm testing. Notification appliances, connections to fire alarm systems, and connections to approved supervising stations shall be tested in accordance with this section and Section 907 to verify proper operation.

Information Only: For alarm test call (816) 696-1300 one business day before needing the alarm tested.

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**