

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20251843  
Address: 1809 NE CHERRYBARK CT, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Failed	Thursday, September 04, 2025

Corrective Action Required:

1	Misc	Garage PFH wall nailing is OK; however, have engineer address braced wall requirement for rear exterior walls at master bedroom and dining room
---	------	---

**Comments:**