

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20250089
Address: 652 SE BRADFREE ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Shawn Hoffman	Not Ready	Friday, September 05, 2025

Corrective Action Required:

1	Miscellaneous Correction	NOT READY
		- No grounding - No bonding - No conductors in meter can or feeding disconnects

Comments: