

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20244682
Address: 19 NE SYCAMORE ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Wes Bears	Partial	Friday, September 05, 2025

Informational:

1 Misc

Conduit trench ok to fill across lot tying buildings 3,4,5 to 1&2
Conduit trench ok to fill that connects service between buildings 3&4
Conduit ok to cover that feeds between light poles in front of building 2;
conduits to 6 light poles at south&west side of building 1 and conduits to 2
light poles at east side of building 2
: 2" conduit connecting north end of building 4 to east end of building 5
:1 1/2" conduit from building 4 to light poles between buildings 4&5
-1/2" conduit for light poles ran roughly 40' from NE side of building 5
-Conduit from north of building 3 west to (3) light poles
-Conduit with fire alarm between 1 and 2 building are good to backfill

Comments: