



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120225, Building Permit - Commercial
Address: 635 SW 2ND ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|------------------------|
| All Rough Inspection - Commercial | John Borns | Partial | Monday, March 26, 2012 |

Corrective Action Required
1 MISC

TOPS OF EXTERIOR WALL CAVITIES TO BE FIREBLOCKED TO PREVENT FIRE COMMUNICATION TO INTERSTITIAL SPACE ABOVE CEILING

Corrective Action Required
2 MISC

FIREBLOCKING REQUIRED AT 10' HORIZONTAL INTERVALS TO PREVENT FIRE TRAVEL WITHIN EXTERIOR WALLS

Corrective Action Required
3 MISC

BOCA PROTECTION PLATES REQUIRED AT PVC PLUMBING STACK

Comments: OK TO INSULATE EXTERIOR WALLS AND ABOVE GWB CEILINGS. OK TO INSTALL GWB AT WALLS AFTER BOCA PLATES ARE IN PLACE PER ABOVE.