

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242774
Address: 1000 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Robb Popp	Partial	Tuesday, September 09, 2025

Corrective Action Required:

1	Misc	-30' Conduit at NW corner of building -20' Conduit at NE corner of building -Secondary conduits from transformer to NE of building - Conduit across West end of wash bays - Conduits from middle of wash bays turn up into equipment room - Conduit from CT cab to transformers on East end -Conduit from building to just short of pump and tank locations ok to cover
---	------	---

Informational:

2	Misc	OK to backfill area west of wash bays
---	------	---------------------------------------

Comments: