

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20250089
Address: 652 SE BRADFEE ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mitchell Schwarz	Not Ready	Tuesday, September 09, 2025

Informational:

1	Misc	Exterior shear wall nailing okay to cover
---	------	---

Corrective Action Required:

2	Misc	Not done 09/09/25
---	------	-------------------

- Strap top plate on exterior wall at managers office, minimum overlap 4'

Comments: