

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251795
Address: 2736 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Khanh Nguyen	Failed	Tuesday, September 09, 2025

Corrective Action Required:

1	Misc	-Support ceiling grid every 4 ft -Secure MC to ceiling light support wire, not grid support wire -Do not drop ceiling tiles. Provide ladder on site at next inspection
---	------	--

Comments: