

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20244966

Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Hydrostatic Test	Jamie Simerly	Passed	Tuesday, September 09, 2025

Informational:

1	Misc	09/08/25 Jamie S, Hydrostatic test on North line tested at 150psi for two hours. Passed.
		09/09/25 Jamie S, Hydrostatic test on South line tested at 150psi for two hours. Passed

Comments: