

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20243938
Address: 1921 NE TRAILS EDGE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Failed	Tuesday, September 09, 2025

Corrective Action Required:

1	Misc	-Exterior shear wall nailing-OK
		In-wall:
		-Fire stop all wall plate penetrations
		-Nail corner studs
		-Protect raceways in prep room
		-Protect plumbing at riser room

****OK TO INSULATE**

Comments: