CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252359

Address: 1308 SE WINDBREAK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Mitchell Schwarz Failed Wednesday,

Residential September 10, 2025

Corrective Action Required:

1 Misc -missing truss hanger on 1 B2 1st floor trusse per plans.

-missing wall stud under B2 trusses entry/garage wall

Comments: