

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245048
Address: 2739 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Wes Bears	Failed	Wednesday, September 10, 2025

Corrective Action Required:

1	Misc	-rail needed on front porch where the drop to the ground is over 30" -light fixtures in the bathroom need to be in place -door between the house and garage needs to be self closing -no power at upstairs bathroom
---	------	--

Comments: