



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20120199, Building Permit - Commercial
Address: 20 NE SYCAMORE ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Electrical Inspection - Commercial	John Borns	Failed	Tuesday, March 27, 2012

Corrective Action Required

1 MISC

PANEL SCHEDULES TO BE VERIFIED

Corrective Action Required

2 MISC

ELECTRICAL RECEPTACLE BELOW COFFEE MACHINES TO BE GFCI PROTECTED

Miscellaneous Inspection

John Borns Failed Tuesday, March 27, 2012

Corrective Action Required

1 MISC

TWO FIRE PROTECTION SPRINKLER HEAD ESCUTCHEONS MISSING AT KITCHEN

Corrective Action Required

2 MISC

INDIVIDUAL BACKFLOW PREVENTION IS REQUIRED AT WATER-FED EQUIPMENT TO PREVENT CROSS-CONTAMINATION

Corrective Action Required

3 MISC

DRAIN TO BE INSTALLED AT ESPRESSO MACHINE

Corrective Action Required

4 MISC

CLEAR ANY ISSUES WITH LS FIRE DEPARTMENT

Comments:

