

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20250070  
Address: 624 SE WOOD LN, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, September 11, 2025

Corrective Action Required:  
2 Misc

- fireblock garage walls into garage furr down
- seal penetrations in draft stoping
- ensure all smoke and smoke/co are not closer than 3' to a bathroom
- provide hold down for each side of double truss above primary bedroom
- missing hold downs on multiple trusses
- Primary bedroom
  - protect dryer vent 2" below top plate
  - T02 trusses entry above primary bedroom does not match plans
  - land all grounds and neutrals
  - install bonding screw at panel

**Comments:**