

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

**Inspection Summary**

Permit #: PRCOM20244252  
Address: 2951 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pool Steel/Bonding - Commercial</b>	Khanh Nguyen	Partial	Thursday, September 11, 2025

**Corrective Action Required:**

1 Misc

Pool components bonded:

-6 light niches, pool shell, handrails bases, pool water at skimmer, bonding jumper to pool equipments room, perimeter bonding jumpers, spa bonding

**\*\*provide product information for the pool potting compound used to protect the bonding jumper connections to light niches**

**Comments:**