

DEVELOPMENT SERVICES

PLAN REVIEW CONDITIONS

September 11, 2025

Clayton Signs, Inc.
5198 North Lake Drive
Lake City, GA 30260

Permit No: PRSGN20252808
Project Title: CHICK FIL A SIGNS
Project Address: 1025 SW JEFFERSON ST, LEES SUMMIT, MO 64081
Parcel Number: 61500036300000000
Location / Legal: LELANDS COMMERCIAL PARK LOT 1
Description:
Type of Work: SIGN
Occupancy Group: NOT APPLICABLE
Description: The scope of work is outlined in the attached drawings. The scope of work includes the following:

- A1: Monument sign, D/F illuminated, 70 square feet
- A2/A3: Tenant panels for multi-tenant signs, quantity 4 (2 for each sign, A2 & A3)
- B: Wall Sign, LED-illuminated channel letters, 37.71 square feet
- C: Wall sign, LED-illuminated channel letters, 37.71 square feet
- D: Wall sign, Illuminated logo cabinet, 36 square feet
- E: Wall sign, LED-illuminated channel letters, 37.71 square feet
- F: Wall sign, welcome wall sign dimensional stamp, 6.25 square feet
- DOT regulatory traffic signs
- H1/H2: Static digital drive-thru menu boards, Qty. 2
- CB-1: Drive-thru clearance bar, Qty. 2
- FP: 25' Flag pole
- Window graphics/address numbers/interior vestibule door graphics/interior playground graphics

Revisions Required

One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and /or additional information to the application through the online portal. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Sign Permit Review

Reviewed By: Ian Trefren

Rejected

1. Proposed signage exceeds the count maximum of the PMIX district for attached wall signage on single-tenant commercial buildings (proposed - 5; maximum - 3). Signs 'D' and 'F' are considered attached wall signs.

DEVELOPMENT SERVICES

2. Confirm that incidental signage adhered to the glass elements (e.g. push/pull decals) will be located on the interior of the pane, such that it will not be exposed to the elements.

3. The process for seeking a modification to the sign count maximum is via a Sign Application, which is reviewed by Planning Commission as part of a consent agenda item.

Sign Permit Review

Reviewed By: Ian Trefren

Rejected

1. To prevent any confusion at the time of inspection, please revise drawings to reflect amended scope of work. Sheets still depict Sign E despite being removed from the elevations.

2. Door graphics indicate that all decals are to be applied to exterior surface. Exterior window signage is prohibited. Please amend accordingly for all signage attached to windows.

Sign Permit Review

Reviewed By: Ian Trefren

Approved

1. Notice for inspection: Revised scope of work includes three (3) attached wall signs, the freestanding monument sign at the SE corner of subject property, and two (2) panels for each of the two (2) Oldham Village monument signs. Additional signage smaller than 1SF exempted from permitting.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.