

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20245783
Address: 2 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Robb Popp	Failed	Thursday, September 11, 2025

Informational:
1 Misc

****The following areas approved:**
-020, 021 OK to cover

West side roof facade to line 4 ok
South side roof facade ok
-CMU Walls at loading dock ok
****Exterior wall and eyebrow framing ok to cover**

-Rms 019, 040, 041, 157 Ok to one side for equipment
-Main floor, south of line 4-OK to one side from ceiling level to top

9/11/25-Partial for 2nd floor-Secure all mc within 12" of boxes

*****OK TO 1 SIDE ONLY AS NEEDED**
-RP

Comments: