



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20120225, Building Permit - Commercial  
Address: 635 SW 2ND ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	John Borns	Partial	Tuesday, March 27, 2012

Corrective Action Required  
1 MISC

TOP OF SOUTH EXTERIOR WALL CAVITY TO BE FIREBLOCKED  
TO PREVENT FIRE COMMUNICATION TO INTERSTITIAL SPACE  
ABOVE CEILING

Partial Correction  
3 MISC

5" TALL BOCA PROTECTION PLATE REQUIRED AT BOTTOM OF  
PVC PLUMBING STACK

**Comments:**