

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244922
Address: 3205 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Wes Bears	Failed	Friday, September 12, 2025

Corrective Action Required:

1	Misc	-egress step from family room to patio IRC# R311.7.5.1 -spark ring needed at island outlets -oven needs lockout at electric panel -address numbers need to be contrasting IRC# R319.1
---	------	--

Comments: