

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20244966

Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Coliform Test 2	Jamie Simerly	Passed	Monday, September 15, 2025

Informational:

1 Misc

9-12-25 Site Rite collected two samples from north and south lines. Samples delivered to Blue Valley Lab for Coliform testing
09/15/25 Jamie S, Noth and South Samples came back negative for the coliform test 2. Passed.

Comments: