

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242774
Address: 1000 NW PRYOR RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Tyler Schreck	Failed	Monday, September 15, 2025

Corrective Action Required:

1	Misc	9/8/25 SW is in compliance with city specs. Approve to pour. 9/15/25 Tyler S. ADA ramp and sidewalk panel on the south west corner has two(2) foot prints in the concrete. Need to be replaced.
---	------	--

Comments: