

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246494
Address: 2734 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|----------|----------------------------|
| Occupancy Inspection - Codes Residential | Mitchell Schwarz | Failed | Monday, September 15, 2025 |

Corrective Action Required:
2 Misc

- obtain issued lawn irrigation permit
- provide spark ring at front entry stone wall and above fireplace
- outlets under kitchen sink must be GFCI PROTECTED
- secure dishwasher drain up above drain

Comments: