

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250632
Address: 2225 SW CROWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, September 16, 2025

Corrective Action Required:

1	Misc	-As-graded plot plan is required -Sod, downspout and sump pump extension -Seal exterior lights, etc -Provide a graspable handrail for garage stair with handrail profile per code
---	------	--

Comments: