

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231814

Address: 2150 NE INDEPENDENCE AVE, LEES SUMMIT, MO 640642201 NE TOWN CENTRE BLVD, LEES
SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Detention Basin		Passed	Tuesday, September 16, 2025

Informational:

1 Misc

9-16-25 NS Site visited, and it appears that the Detention Basin drains the water within the 40-hour time frame. The drain was plugged and would not let it drain in that time. They fixed that and the vegetation has grown in correctly. Passed as of right now.

Comments: