

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252473
Address: 1408 NE ERNEST WAY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Inspection - Residential	Khanh Nguyen	Failed	Tuesday, September 16, 2025

Corrective Action Required:

1	Misc	-Provide #4 cu ungrounded conductors per plan -Bond metal raceway -Enclose PV #4 grounding electrode conductor inside raceway -Ground PV meter to rod -Provide permanent AC rating label that can withstand weather, no handwriting -Install plaque per 705
---	------	--

Comments: