

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251547

Address: 2751 NE DOUGLAS ST, Unit:12, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Khanh Nguyen	Failed	Tuesday, September 16, 2025

Corrective Action Required:

1	Misc	-Install blockings for ADA grab bars -Install ducting for bath fans -Protect plumbing at west restroom urinal
---	------	---

Comments: