

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244751
Address: 1025 SW ARMIE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Wednesday, September 17, 2025

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | - Seal exterior penetrations at gas meter |
| | | - Electrical receptacle in garage near attic access not GFCI protected |
| | | - Uncover smoke detectors |
| | | - Uncover water meter for inspection |

Comments: