

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250603
Address: 2524 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Khanh Nguyen	Failed	Thursday, September 18, 2025

Corrective Action Required:

1	Misc	REQUESTED INSPECTION(S) DENIED DUE TO DEFICIENT EROSION CONTROL INSTALLATION.
		EROSION CONTROL SHALL BE INSTALLED ALONG THE STREET AND ALONG THE REAR OF LOT. PROVIDE EROSION CONTROL AT REAR STORM INLETS

Comments: