



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114738, Building Permit - Commercial
Address: 1702 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Partial	Wednesday, March 28, 2012

Corrective Action Required
2 MISC

ANSI/ICC 604.5.1: 18" VERTICAL GRAB BAR REQUIRED AT EACH
PUBLIC RESTROOM SIDE WALL

Comments: