

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250070
Address: 624 SE WOOD LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, September 18, 2025

Corrective Action Required:

1	Misc	no plans on site
		-fireblock garage walls into garage furr down
		-
		-ensure all smoke and smoke/co are not closer than 3' to a bathroom
		-
		-
		-T02 trusses entry above primary bedroom does not match plans

Comments: