

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250888
Address: 2622 SW FIREFLY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Failed	Thursday, September 18, 2025

Corrective Action Required:

1	Misc	2622 SW Firefly Ln
		- As graded plot plan needed
		- Driveway inspection needed
		- Gfci for dishwasher doesn't function
		- Final grade and sod needed
		- Splash blocks need installed
		- Sewer tracer wire needs landed in box
		- Outlet needed within 25' of exterior AC unit

Comments: