

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250046
Address: 636 SE WOOD LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, September 18, 2025

Corrective Action Required:

1	Misc	Truss plans must be city approved. -fireblock garage walls into furr down seal penetrations and gaps in draft stopping -provide hold downs both sides of double truss above bed 1 closet (not catching both plates)
---	------	--

Comments: