



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20243938	Date:	September 18, 2025
Project Title:	THE VILLAGE AT DISCOVERY PET SPA	Applicant:	
Location:			
1921 NE TRAILS EDGE BLVD, LEES SUMMIT, MO 64064	ALLIANCE FIRE PROTECTION LLC		
Type of Work:	130 W 9TH AVE STE 101		
Occupancy Group:	KANSAS CITY, MO 64116		
Description:	DISCOVERY PET SPA - NEW	Primary:	(913) 888-0647
BUILDING FOR PET GROOMING AND KENNELING			
Construction Type:	Type VB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Craig Hill

Released for Construction

Alarm Plan Review

Reviewed By: Craig Hill

Rejected

1. Notification needs to be added to comply with IFC 2018 and NFPA 72.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.