

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250069
Address: 640 SE WOOD LN, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, September 18, 2025

Corrective Action Required:

1	Misc	Truss plans must be city approved. -fireblock garage walls into furr down -end condition 4 call out in blue prints does not have detail -stair truss repair not nailed to stamped fix -seal penetrations and gaps in draft stopping -T02 truss above primary bedroom does not match plans
---	------	--

Comments: