

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20253208

Address: 207 NW ORCHARD CT, LEES SUMMIT, MO 64063205 NW ORCHARD CT, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Not Ready	Monday, September 22, 2025

Corrective Action Required:

1	Misc	Note carried over from previous rated assembly: Unit 207- fire tape attic space, seal all gaps and penetrations (provide ladder to verify) 9/22/25 -Not ready for inspection. Fee assessed. Inspection incomplete. Pay all fees due before occupancy -Provide as graded plot plan including retaining wall -Complete exterior stairs -Garage stairs vary more than 3/8" -Driveway inspection still pending -Install security screws per LS chapter 7 at entry door -Remove all furniture for inspection
---	------	--

Comments: