

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252573
Address: 2630 SW FIREFLY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Drew Fischer	Failed	Monday, September 22, 2025

Informational:

1	Misc	Garage portal frame ok Front and back porch ok to cover
---	------	--

Corrective Action Required:

2	Misc	2630 SW Firefly - Bath fans are missing flex vent ducts - Fire blocking needed each side of window in bedroom 2, wall space into soffit - One column in basement missing bolt to floor -
---	------	--

Comments: