

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20244682
Address: 19 NE SYCAMORE ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection	John Jackson	Partial	Wednesday, September 24, 2025

Informational:

1	Misc	06/13/25 Friday JMJ (Level) Talked to contractor about cleaning up Main St. & Sycamore from soil being track-out into the street.
		07/03/25 Thursday JMJ (Level) Talked with contractor about keeping the street clean Bash Excavating is removing soil.
		07/17/25 Friday JMJ (Level) Contractor needs to repair silt fencing, clean adjacent streets, and trim vegetation around project.
		08/12/25 Tuesday JMJ (Level) Erosion control inspection appears to be functioning.
		09/03/25 Wednesday JMJ (Level) Contractor needs to reestablish silt fencing Northside of project.

Comments: