

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245749
Address: 2524 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Ready for Temp CO	Wednesday, September 24, 2025

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | -Deck piers not inspected by city. Provide foundation piers plan and engineer inspection report for the piers. |
| | | -Final grade, sod, downspout and sump pump extension |
| | | -Provide sewer tracer wire port at grade; bring sewer valve access to grade |
| | | -Provide kitchen countertops receptacles per code **Provide documentation for the countertop receptacles |
| | | -Complete upper and lower deck |

Comments: