

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20252490
Address: 910 NW BLUE PKWY, Unit:W, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Failed	Wednesday, September 24, 2025

Corrective Action Required:

1	Misc	-Remove unused fitting at J box in soffit, install knockout cover, and provide access panel in soffit near hall 105. This can be verified at final
---	------	--

****9/24/25**

-Inspection requested for fire alarm-contact LSFD

Comments: