

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

Inspection Summary

Permit #: PRCOM20115556, Building Permit - Commercial Address: 130 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Gas Piping John Borns Partial Friday, March 30, 2012

Inspection - Commercial

Partial Correction

MISC PRESSURE TEST ON GAS PIPING TO RTU's HELD STEADY AT >

10 PSI FOR > 20 MIN. APPROVED

Corrective Action Required

2 MISC BEFORE FINAL INSPECTION SUPPORT GAS PIPING PER

INTERNATIONAL FUEL GAS CODE + PAINT PIPING TO PREVENT

CORROSION.

Comments: