

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246287

Address: 1344 SW WINTHROP TER, LEES SUMMIT, MO 640811342 SW WINTHROP TER, LEES SUMMIT, MO
64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Partial	Thursday, September 25, 2025

Informational:

1 Misc

9-25-25 Dustin A, Walked with contractor to discuss sidewalk. 2 landings will be required due to slope. Also showed them where they needed to attach to existing sidewalk, They will be attaching to the panel with the water valve currently in sidewalk.

Comments: