

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250844
Address: 2611 SW FIREFLY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Tyler Schreck	Passed	Monday, September 29, 2025

Corrective Action Required:

1	Misc	8/6/25 Tyler S. SW is formed and compacted. Slopes are in compliance. Approved to pour. 8/13/25 Tyler S. SW appear to meet city code and ADA is in compliance. Cant pass at this time due to the forms not being pulled. 9/29/25 Tyler S. Sw is in compliance with ADA and city specs.
---	------	--

Comments: