

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20251486
Address: 1043 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Ready for Temp CO	Monday, September 29, 2025

Corrective Action Required:

1 Misc

- Remove and protect spoils pile in back of lot
- Sump discharge to be 36" away from foundation
- Final grading and sod
- Provide splash pads at down spouts
- Final driveway inspection pending

Comments: